

Date: October 15, 2024	Addendum #: 01
Project: Boise Centre 200 Offices Refresh	Project #: 24012.01
Address: 850 W Front St, Boise, ID 83702	

To All Planholders: Please notify everyone concerned as your sub-contractors and suppliers of the issuance and contents of this addendum prior to date of bid opening.

EXISTING CONDITIONS

Second Floor 200 Offices Ceiling Heights:

- Approximate ceiling heights for locations receiving wall covering (**WC1**) and (**WC2**):
 - o Room 200: 12' - 6"
 - o Lobby 203: 12' - 6"
 - o Hall 220: 10'- 1"
 - o DF Alcove 223: 9' - 0"
 - o Hall 224: 10' - 1"
 - o Alcove 227: 12' - 6"
 - o Hall 229: 8' - 4"

- Contractor to field-verify all material takeoffs, dimensions and existing conditions.

ATTACHMENT LIST:

N/A